



Switching between stabilizing controllers[☆]

João P. Hespanha^{a,*,1}, A. Stephen Morse^{b,2}

^aDepartment of Electrical and Computer Engineering, University of California, Engineering I, Room 5157, Santa Barbara, CA 93106-9560, USA

^bDepartment of Electrical Engineering, Yale University, New Haven, CT06520-8267, USA

Received 12 May 2000; received in revised form 17 November 2001; accepted 18 June 2002

Abstract

This paper deals with the problem of switching between several linear time-invariant (LTI) controllers—all of them capable of stabilizing a specific LTI process—in such a way that the stability of the closed-loop system is guaranteed for any switching sequence. We show that it is possible to find realizations for any given family of controller transfer matrices so that the closed-loop system remains stable, no matter how we switch among the controller. The motivation for this problem is the control of complex systems where conflicting requirements make a single LTI controller unsuitable.

© 2002 Published by Elsevier Science Ltd.

Keywords: Switched systems; Impulse system; Hybrid systems; Realization theory; Stability theory

1. Introduction

Given a finite set of matrices $\mathcal{A} := \{A_p: p \in \mathcal{P}\}$, consider the linear time-varying system

$$\dot{x} = A_\sigma x, \tag{1}$$

where σ denotes a piecewise constant “switching signal” taking values on \mathcal{P} . The following question has often been posed: “Under what conditions is the system (1) uniformly asymptotically stable for every piecewise constant switching signal σ ?” (Molchanov & Pyatnitskiy, 1989; Narendra & Balakrishnan, 1994; Boyd, Ghaoui, Feron, & Balakrishnan, 1994; Morse, 1995; Gurvits, 1996; Tsitsiklis & Blondel, 1997; Shorten & Narendra, 1997; Yoshihiro Mori & Kuroe, 1997; Dayawansa & Martin, 1999; Liberzon, Hespanha, & Morse, 1999; Liberzon, & Morse, 1999). In Gurvits (1996) it is shown that uniform asymptotic stability of (1) for every switching signal σ is equivalent to the existence of an

induced norm $\|\cdot\|_*$ and a positive constant α such that

$$\|e^{At}\|_* \leq e^{-\alpha t} \quad \forall t \geq 0, \quad \forall A \in \mathcal{A}.$$

In Dayawansa and Martin (1999) it is shown that uniform asymptotic stability of (1) for every switching signal σ is also equivalent to the existence of a common Lyapunov function (not necessarily quadratic) for the family of linear time-invariant systems $\{\dot{z} = A_p z: p \in \mathcal{P}\}$. However, the proofs in Gurvits (1996), Dayawansa and Martin (1999) are not constructive and not amenable to test the stability of general switched system. By Narendra and Balakrishnan (1994), Shorten and Narendra (1997), Liberzon et al. (1999) provide simple algebraic conditions on the elements of \mathcal{A} , which are sufficient for the existence of a common quadratic Lyapunov function for the family of linear time-invariant systems $\{\dot{z} = A_p z: p \in \mathcal{P}\}$, and therefore for the uniform asymptotic stability of (1) for every switching signal σ . However, it is known that none of these conditions are necessary for the stability of the switched system. For more on this topic see Boyd et al. (1994), Morse (1995), Liberzon and Morse (1999) and references therein.

A simple and general test to check the uniform asymptotic stability of (1), for every switching signal σ , has eluded researchers for more than a decade. However, when systems like (1) arise in control problems, in general, the matrices in \mathcal{A} have specific structures. In fact, these matrices are often obtained from the feedback connection of a fixed process with one of several controllers, and the

[☆] This paper was not presented at any IFAC meeting. This paper was recommended for publication in revised form by the Associate Editor Per-Olof Gutman under the direction of Editor Tamer Basar.

* Corresponding author.

E-mail address: hespanha@ece.ucsb.edu (J.P. Hespanha).

¹ Supported by the National Science Foundation (Grant No. ECS-0093762).

² Supported by the Air Force Office of Scientific Research, and the Army Research Office.

switching signal σ determines which controller is in the feedback loop at each instant of time. One can then pose the question if, by appropriate choice of the realizations for the controllers, it is possible to make the system (1) uniformly asymptotically stable for every switching signal σ . This is precisely the question addressed in this paper. The motivation for this problem is the control of complex systems where conflicting requirements make a single linear time-invariant controller unsuitable. The reader is referred to Boyd and Barratt (1991) for a detailed discussion on the tradeoffs that arise when a single linear controller is used to meet multiple performance specifications (e.g., involving bandwidth, time response, robustness with respect to modeling errors, etc.). Controller switching to improve the tradeoff in design objectives has been proposed in a few papers. In Hespanha and Morse (1996), a logic was devised to orchestrate the switching between several controllers, some with high-performance/low-robustness and others with low-performance/high-robustness. In Eker and Malmberg (1999), switching among PID controllers was used to achieve fast step response without overshoot. In Section 5, we illustrate the use of switching in the control of the roll angle of an aircraft. We design two controllers: the first is slow but has good noise rejection properties, whereas the second is fast but very sensitive to measurement noise. By switching between the controllers, we are able to achieve good noise rejection when the noise is large and yet obtain a fast response when the noise is small (cf. Fig. 6). The method used to implement the switching controller guarantees stability *regardless of the algorithm used to command the switching between the controllers*. This means that one can use simple-minded algorithms to switch between the two controllers, without fear of causing instability.

In this paper, we assume that the process \mathbf{P} to be controlled is modeled by a linear, time-invariant, stabilizable and detectable system of the form

$$\dot{x}_{\mathbf{P}} = A_{\mathbf{P}}x_{\mathbf{P}} + Bu, \quad y = Cx_{\mathbf{P}}. \quad (2)$$

We take as given a family of controller transfer matrices $\mathcal{K} := \{K_p; p \in \mathcal{P}\}$ with the property that, for each $p \in \mathcal{P}$, the feedback interconnection of (2) with any stabilizable and detectable realization of K_p is asymptotically stable. Let then $\dot{x}_p = A_p x_p$ denote the system that results from the p th such interconnection. The main result of this paper is to prove that if the controller realizations are chosen properly, then for any piecewise constant signal $\sigma: [0, \infty) \rightarrow \mathcal{P}$, the switched system

$$\dot{x} = A_{\sigma}x \quad (3)$$

will be uniformly exponentially stable. That the stability of (3) should be controller realization dependent is not surprising, but the fact that there is actually a way to realize the controllers that is guaranteed to achieve stability for every σ perhaps is. The approach we use to establish this result relies on the fact that all the controller transfer matrices can be expressed using the Youla parameterization with a distinct

value of the Youla parameter for each controller (Youla, Jabr, & Bongiorno, 1976). Switching between controllers can thus be reduced to switching between the corresponding values of the parameter. The same idea has been independently discovered by Packard (1995) but was not published.

The Youla parameters used to represent the controller transfer matrices in \mathcal{K} are stable transfer matrices. An important step in the overall controller realization procedure is to select realizations for the individual Youla parameters so that switching between them results in a stable time-varying system $\mathbf{S}(\sigma)$. There are two ways to accomplish this: The first is to develop realizations for the Youla parameters for which there is a common Lyapunov function. In the second, the state of $\mathbf{S}(\sigma)$ is reset at switching times resulting in what is often called a “system with impulse effects”. We show that both approaches are possible. The idea of resetting part of the controller state dates as far back as the 1950s with the Clegg Integrator (Clegg, 1958) and later with Horowitz and Rosenbaum’s first-order reset elements (FORE) (Horowitz & Rosenbaum, 1975). The reader is referred to (Holot, Beker, & Chait, 2001) for more recent references on this form of “reset control”, whose goal is to improve transient performance.

The problem addressed in this paper is precisely formulated in Section 2. In Section 3, we derive some basic results to study the stability of systems with impulse effects. These results are used in Section 4 to construct the desired realizations for the controller transfer functions: in 4.1, we motivate the construction by considering the simpler case of a single-input/single-output stable process and in 4.2, we address the general case. A simple illustrative example is presented in Section 5. Section 6 contains some concluding remarks and directions for future research. A preliminary version of the results in this paper was presented at the 12th International Symposium on the Mathematical Theory of Networks and Systematics, St. Louis, MO, June 1996. These were subsequently improved in the Ph.D. thesis (Hespanha, 1998).

2. Stable controller switching

The feedback configuration used in this paper is shown in Fig. 1. In this figure, u denotes the control input, y the process output, \mathbf{r} a bounded reference signal, \mathbf{d} an unknown but bounded input disturbance, and \mathbf{n} unknown but bounded measurement noise. The process will be denoted by \mathbf{P} and is




Fig. 1. Feedback configuration.

assumed to be a multivariable linear time-invariant system with strictly proper transfer matrix H_P . We say that a given controller transfer matrix K stabilizes H_P if, for any stabilizable and detectable realizations $\{A, B, C\}$ and $\{F, G, H, J\}$ of H_P and K , respectively, the feedback connection shown in Fig. 1 is asymptotically stable, i.e., all the poles of the matrix

$$\begin{bmatrix} A - BJC & BH \\ -GC & F \end{bmatrix} \quad (4)$$

have negative real part. We recall that a quadruple of matrices $\{A, B, C, D\}$ is called a realization for a transfer matrix H if $H(s) = C(sI - A)^{-1}B + D$ for every $s \in \mathbb{C}$. When the matrix D is equal to zero one often writes simply that $\{A, B, C\}$ is a realization for H .

Consider now a finite set of controller transfer matrices $\mathcal{K} = \{K_p: p \in \mathcal{P}\}$ each stabilizing the process transfer matrix H_P . The general problem under consideration is to build a “multi-controller” that effectively switches among the transfer functions in \mathcal{K} . In this context, a multi-controller is a dynamical system $C(\sigma)$ with two inputs σ, \mathbf{e}_T and one output u_C . The input $\sigma: [0, \infty) \rightarrow \mathcal{P}$ is piecewise constant and is called a switching signal. While σ remains constant and equal to some $p \in \mathcal{P}$, $C(\sigma)$ is required to behave as a linear time-invariant system with transfer function K_p from its input \mathbf{e}_T to its output u_C . The multi-controller design problem is nontrivial because we also require that all the closed-loop signals remain bounded for every possible switching signal in the set \mathcal{S} of all piecewise constant switching signals. The times at which a signal $\sigma \in \mathcal{S}$ is discontinuous are called the switching times of σ . For simplicity of notation we take all signals in \mathcal{S} to be continuous from above at switching times, i.e., if t_1 and t_2 are two consecutive switching times of $\sigma \in \mathcal{S}$ then σ is constant on $[t_1, t_2)$.

To build a multi-controller we start by selecting n_C -dimensional stabilizable and detectable realizations $\{F_p, G_p, H_p, J_p\}$ for each K_p in \mathcal{K} . Over any open interval on which a switching signal $\sigma \in \mathcal{S}$ is constant, the multi-controller $C(\sigma)$ is then defined by the following dynamical system

$$\dot{x}_C = F_\sigma x_C + G_\sigma \mathbf{e}_T, \quad u_C = H_\sigma x_C + J_\sigma \mathbf{e}_T \quad (5)$$

which possesses the desired transfer function from \mathbf{e}_T to u_C . By itself, (5) does not determine what happens to x_C at the switching times of σ . A rule must therefore be specified to determine the value of x_C immediately after a switching time. Such a rule takes the general form³

$$x_C(t) = r(x_C(t^-); \sigma(t), \sigma(t^-)),$$

³ Here and in the sequel, given a signal z we denote by $z(t^-)$ the limit of $z(\tau)$ as $\tau \rightarrow t$ from below, i.e., $z(t^-) := \lim_{\tau \uparrow t} z(\tau)$. Without loss of generality we take x_C to be continuous from above at every point, i.e., $x_C(t) = \lim_{\tau \downarrow t} x_C(\tau)$.




Fig. 2. Feedback connection between P and $C(\sigma)$.

where $r: \mathbb{R}^{n_C} \times \mathcal{P} \times \mathcal{P} \rightarrow \mathbb{R}^{n_C}$ is called a reset map. In this paper, we restrict reset maps to be linear functions of x_C , i.e.,

$$x_C(t) = R_C(\sigma(t), \sigma(t^-))x_C(t^-), \quad (6)$$

where the $R_C(p, q) \in \mathbb{R}^{n_C \times n_C}$, $p, q \in \mathcal{P}$, are called reset matrices. Systems like the one defined by (5)–(6) are often called systems with impulse effects (cf. Bainov & Simeonov, 1989; Ye, Michel, & Hou, 1998 and references therein).

Consider now the feedback connection between $C(\sigma)$ and P in Fig. 2 and let $\{A, B, C\}$ denote an n_P -dimensional stabilizable and detectable realization for the process transfer function H_P . Over any open interval on which $\sigma \in \mathcal{S}$ is constant, the feedback connection in Fig. 2 corresponds to the dynamical system

$$\dot{x} = A_\sigma x + B_\sigma w, \quad y = Cx \quad (7)$$

with $x := [x'_P \ x'_C]'$, $w := [d' \ r' - n']'$, $C := [C \ 0]$, and

$$A_p := \begin{bmatrix} A - B J_p C & B H_p \\ -G_p C & F_p \end{bmatrix}, \quad B_p := \begin{bmatrix} B & 0 \\ 0 & G_p \end{bmatrix}, \quad p \in \mathcal{P}; \quad (8)$$

whereas, at a switching time t ,

$$x(t) = R(\sigma(t), \sigma(t^-))x(t^-) \quad (9)$$

with

$$R(p, q) := \begin{bmatrix} I_{n_P} & 0 \\ 0 & R_C(p, q) \end{bmatrix}, \quad p, q \in \mathcal{P}. \quad (10)$$

Since each transfer matrix in \mathcal{K} stabilizes H_P , (7) is asymptotically stable for any constant $\sigma(t) = p \in \mathcal{P}$, $t \geq 0$. But, in general, this is not enough to guarantee that the state of (7)–(9) remains bounded for every $\sigma \in \mathcal{S}$. Examples of unstable behavior resulting from the switching amount stable systems are well known and can be found, e.g., in Branicky (1998) or the recent survey (Liberzon & Morse, 1999).

The problem under consideration can then be summarized as follows: Given the family \mathcal{K} of controller transfer functions, compute reset matrices and realizations for the transfer functions in \mathcal{K} so that the state x of the closed-loop switched system (7)–(9) remains bounded for every switching signal $\sigma \in \mathcal{S}$ and every bounded piecewise continuous exogenous inputs \mathbf{r}, \mathbf{n} , and \mathbf{d} . We shall also require x to decay to zero, when $\mathbf{r} = \mathbf{d} = \mathbf{n} = 0$.

In this paper, we assume that the set of controllers is finite just for simplicity. The finiteness assumption could be replaced by appropriate uniformity assumptions. For example, one could require compactness of \mathcal{P} and continuity of

the coefficients of the controller transfer matrices with respect to the parameter p .

3. Stability of systems with impulse effects

Consider the n -dimensional homogeneous linear system with impulse effects defined by

$$\dot{z} = A_\sigma z, \tag{11}$$

on intervals where the switching signal $\sigma \in \mathcal{S}$ remains constant, and by

$$z(t) = R(\sigma(t), \sigma(t^-))z(t^-) \tag{12}$$

at each switching time t of σ . The solution to (11)–(12) can be written as

$$z(t) = \Phi(t, t_0; \sigma)z(t_0), \quad t, t_0 \in \mathbb{R}, \tag{13}$$

where $\Phi(t, t_0; \sigma)$ denotes the *state-transition matrix* of (11)–(12) and is defined by

$$\Phi(t, t_0; \sigma) := e^{(t-t_m)A_{\sigma(t_m)}} \prod_{k=1}^{m-1} R(\sigma(t_{k+1}), \sigma(t_k)) e^{(t_{k+1}-t_k)A_{\sigma(t_k)}}.$$

Here $\{t_1, t_2, \dots, t_m\}$ denote the switching times of σ in the interval $(t_0, t]$. The system (11)–(12) is called *exponentially stable, uniformly over \mathcal{S}* , if there exist positive constants c, λ such that,⁴ for every $\sigma \in \mathcal{S}$,

$$\|\Phi(t, t_0; \sigma)\| \leq c e^{-\lambda(t-t_0)} \quad \forall t, t_0 \geq 0. \tag{14}$$

State-transition matrices of systems with impulse effects share many of the properties of the usual state transition matrices for linear systems.⁵ In particular, for any $\sigma \in \mathcal{S}$ and $\tau \in \mathbb{R}$, (i) $\Phi(\tau, \tau; \sigma) = I_n$, (ii)

$$\frac{d}{dt} \Phi(t, \tau; \sigma) = A_{\sigma(t)} \Phi(t, \tau; \sigma)$$

for t in the interior of an interval on which $\sigma \in \mathcal{S}$ is constant, and (iii)

$$\Phi(t, \tau; \sigma) = R(\sigma(t), \sigma(t^-))\Phi(t^-, \tau; \sigma)$$

for each switching time t . From the previous properties it is also straightforward to conclude that the variation of constants formula holds for non-homogeneous systems with impulse effects. In fact, the solution to the system defined by

$$\dot{x} = A_\sigma x + B_\sigma w \tag{15}$$

on intervals where $\sigma \in \mathcal{S}$ remains constant and by

$$x(t) = R(\sigma(t), \sigma(t^-))x(t^-) \tag{16}$$

at each switching time t of σ , can be written as

$$x(t) = \Phi(t, t_0; \sigma)x(t_0) + \int_{t_0}^t \Phi(t, \tau)B_{\sigma(\tau)}w(\tau) d\tau, \tag{17}$$

$t, t_0 \in \mathbb{R}$.

It is then straightforward to show that x will remain bounded for every $\sigma \in \mathcal{S}$ and bounded piecewise continuous w , as long as (11)–(12) is exponentially stable, uniformly over \mathcal{S} .

Suppose now that there exist symmetric, positive definite matrices $\{Q_p \in \mathbb{R}^{n \times n}: p \in \mathcal{P}\}$, such that

$$Q_p A_p + A_p' Q_p < 0, \quad p \in \mathcal{P} \tag{18}$$

and

$$R(p, q)' Q_p R(p, q) \leq Q_q, \quad p, q \in \mathcal{P}. \tag{19}$$

Eq. (18) guarantees that, on any interval where σ remains constant and equal to $p \in \mathcal{P}$, the positive definite Lyapunov-like function $V_p(z) := z' Q_p z$, decreases exponentially along solutions to (11). Indeed, on such an interval

$$\begin{aligned} \frac{d}{dt} V_p(z(t)) &= z(t)'(Q_p A_p + A_p' Q_p)z(t) \\ &\leq -2\lambda V_p(z(t)) \end{aligned} \tag{20}$$

for sufficiently small $\lambda > 0$. Moreover, because of (19), when σ switches from $q := \sigma(t^-)$ to $p := \sigma(t)$, we have

$$\begin{aligned} V_p(z(t)) &:= z(t)' Q_p z(t) = z(t^-)' R(p, q)' Q_p R(p, q) z(t^-) \\ &\leq z(t^-)' Q_q z(t^-) =: V_q(z(t^-)). \end{aligned} \tag{21}$$

From (20)–(21) we then conclude that

$$V_{\sigma(t)}(z(t)) \leq e^{-2\lambda(t-t_0)} V_{\sigma(t_0)}(z(t_0)), \quad t \geq t_0, \tag{22}$$

along solutions to (11)–(12). Note that $V_{\sigma(t)}(z(t))$ may be discontinuous at switching times but its value will always decrease at these times because of (21). Since $V_{\sigma(t)}(z(t))$ is quadratic and the Q_p are positive definite, from (22) we actually conclude that

$$\|z(t)\| \leq c e^{-\lambda(t-t_0)} \|z(t_0)\|,$$

with $c := \max_{p, q \in \mathcal{P}} \|Q_p\| \|Q_q^{-1}\|$. This and (13) prove that (14) holds true for every $\sigma \in \mathcal{S}$ and therefore (11)–(12) is exponentially stable, uniformly over \mathcal{S} . Similar analysis using multiple Lyapunov functions can be found, e.g., in Ye et al. (1998), Branicky (1998), in the context of hybrid systems. The following can then be stated:

Lemma 1. *Assume that there exist symmetric matrices $\{Q_p \in \mathbb{R}^{n \times n}: p \in \mathcal{P}\}$, for which (18)–(19) hold. Then the homogeneous system (11)–(12) is exponentially stable, uniformly over \mathcal{S} . Moreover, for every switching signal $\sigma \in \mathcal{S}$ and every bounded piecewise continuous signal w , the state x of the non-homogeneous system (15)–(16) is bounded.*

⁴ Given a vector v and a matrix A we denote by $\|v\|$ and $\|A\|$ the Euclidean norm of v and the largest singular value of A , respectively.

⁵ However, one should keep in mind that Φ does not share all properties of the usual state transition matrices, e.g., it may become singular.

It is interesting to consider two special cases of the previous result. The first corresponds to a complete state reset, i.e., $R(p, q) = 0$, for all $p, q \in \mathcal{P}$. In this case, (19) is trivially true and the only requirement for the stability of the switched system is that each A_p be asymptotically stable. Note that this is enough for the existence of the positive definite matrices $\{Q_p: p \in \mathcal{P}\}$ for which (18) holds.

Another important case is the absence of state reset, i.e., when all the $R(p, q)$, $p, q \in \mathcal{P}$, are equal to the identity matrix. In this case, (19) actually requires all the Q_p to be the same because it demands both $Q_p \leq Q_q$ and $Q_q \leq Q_p$, for all $p, q \in \mathcal{P}$. Inequalities (18)–(19) then demand the existence of a common Lyapunov function for the family of linear time-invariant systems $\{\dot{z} = A_p z: p \in \mathcal{P}\}$. This is a well-known sufficient condition for the exponential stability of the switched system (7). Later, we will see that it is actually possible to always choose realizations for the controllers so that a common Lyapunov function exists for the closed-loop systems. This avoids the need to reset the state of the controllers.

In the remainder of this paper we address the question of computing reset matrices and realizations for the transfer functions in \mathcal{K} so that (18)–(19) hold for the closed-loop matrices A_p in (8). Because of Lemma 1, this will guarantee that, for every switching signal $\sigma \in \mathcal{S}$ and every bounded piecewise continuous exogenous signals \mathbf{r} , \mathbf{n} , and \mathbf{d} , the state x of (7)–(9) is bounded. Moreover, when $\mathbf{r} = \mathbf{d} = \mathbf{n} = 0$, x decays to zero exponentially fast with a rate of decay that is independent of σ . Before proceeding two remarks should be made about Lemma 1:

Remark 2. The exponential stability of (11)–(12) guarantees that system (7)–(9) remains stable under small perturbations to the dynamics of the system. A detailed discussion of this issue for systems without impulsive effects can be found, e.g., in Khalil (1992), Section 4.5. It is straightforward to extend these results to the systems considered here.

Remark 3. In case the Lyapunov inequalities (18) were replaced by the Riccati inequalities

$$Q_p A_p + A_p' Q_p + C_p' C_p + \gamma^{-2} Q_p B_p B_p' Q_p \leq 0, \quad p \in \mathcal{P},$$

then we would actually be able to conclude that the \mathcal{L}_2 induced norm from w to

$$y := C_\sigma x$$

is no larger than γ , along trajectories of the switched system (18)–(19). This could be proved by showing that

$$V_{\sigma(t)}(z(t)) := z(t)' Q_{\sigma(t)} z(t) + \int_0^t (\|y\|^2 - \gamma^2 \|w\|^2) d\tau$$

is nonincreasing, and therefore that

$$\int_0^t (\|y\|^2 - \gamma^2 \|w\|^2) d\tau \leq -z(t)' Q_{\sigma(t)} z(t) \leq 0,$$




Fig. 3. Block diagram corresponding to Eq. (25). The transfer function from e_T to u_C is given by (24), which expresses K_p in terms of S_p (stable process case).

for zero initial conditions. Analogous results could be derived to establish the dissipativeness of (18)–(19), as well as more general integral quadratic constraints (Megretski & Rantzer, 1997) that can be expressed in terms of linear and bilinear matrix inequalities (Boyd et al., 1994).

4. Realizations for controller transfer matrices

We now return to the problem formulated in Section 2. To motivate the approach we start by considering the case of a single-input/single-output asymptotically stable process.

4.1. Single-input/single-output stable process

Suppose we connect the process to a controller with transfer function K_p , $p \in \mathcal{P}$, as in Fig. 1. The transfer function from \mathbf{r} to u_C is then given by

$$S_p := \frac{K_p}{1 + K_p H_P}. \tag{23}$$

Since K_p stabilizes H_P , S_p must be asymptotically stable. From (23) we also conclude that

$$K_p = \frac{S_p}{1 - H_P S_p}, \tag{24}$$

and therefore the transfer function K_p from e_T to u_C can be defined implicitly by the following system of equations⁶ (cf. Fig. 3):

$$u_C = S_p \circ e, \quad e := H_P \circ u_C + e_T. \tag{25}$$

Since only S_p in (25) changes from controller to controller, this suggests a mechanism for switching among the controller transfer functions in \mathcal{K} :

- (1) Pick stabilizable and detectable n_S -dimensional realizations $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ for each S_p , $p \in \mathcal{P}$, defined by (23).

⁶ Given a transfer matrix $H: \mathbb{C} \rightarrow \mathbb{C}^{m \times n}$ and a piecewise constant signal $u: [0, \infty) \rightarrow \mathbb{R}^n$, $H \circ u$ denotes the signal defined by the convolution of the impulse response of H with u .




Fig. 4. Multicontroller $C(\sigma)$ inspired by the implicit definition of K_p given by (25) and the corresponding block diagram in Fig. 3 (stable process case).




Fig. 5. Feedback connection between P and $C(\sigma)$.

(2) Define $S(\sigma)$ to be the system with impulse effects defined by

$$\dot{x} = \bar{A}_\sigma x + \bar{B}_\sigma e, \quad u_C = \bar{C}_\sigma x + \bar{D}_\sigma e,$$

on intervals where σ is constant and by

$$x(t) = \bar{R}(\sigma(t), \sigma(t^-))x(t^-),$$

at each switching time t of σ . For the time being we do not commit to a particular choice for the reset matrices $\{\bar{R}(p, q): p, q \in \mathcal{P}\}$.

(3) Inspired by the implicit definition of K_p given by (25) (and the corresponding block diagram in Fig. 3), we realize the switching controller as in Fig. 4. This corresponds to the multi-controller in (5)–(6) with

$$F_p := \begin{bmatrix} A & B\bar{C}_p \\ \bar{B}_p C & \bar{A}_p \end{bmatrix}, \quad G_p := \begin{bmatrix} B\bar{D}_p \\ \bar{B}_p \end{bmatrix},$$

$$H_p := [\bar{D}_p C \quad \bar{C}_p], \quad J_p := \bar{D}_p$$

and

$$R_C(p, q) := \begin{bmatrix} I & 0 \\ 0 & \bar{R}(p, q) \end{bmatrix},$$

where $\{A, B, C\}$ is a stabilizable and detectable realization for H_P .

Suppose now that we connect this multi-controller to the process as in Fig. 5. Because the process is stable, no matter what u_C turns out to be, we have

$$e = e_T + H_P \circ u_C + \varepsilon_1, \tag{26}$$

where $\varepsilon_1(t)$ is a signal that converges to zero exponentially fast and is due to nonzero initial conditions in the “copy”

of the process inside the multi-controller. Also, for any u_C ,

$$e_T = r - n - H_P \circ (u_C + d) + \varepsilon_2, \tag{27}$$

where $\varepsilon_2(t)$ also converges to zero exponentially fast and is due to nonzero initial conditions in the “real” process. From (26)–(27) we then conclude that

$$e = r - n - H_P \circ d + \varepsilon_1 + \varepsilon_2. \tag{28}$$

This shows that e is independent of σ and will remain bounded, provided that r, n , and d are bounded.

Suppose now that we choose the reset matrices $\{\bar{R}(p, q): p, q \in \mathcal{P}\}$ so that there exist symmetric, positive definite matrices $\{\bar{Q}_p \in \mathbb{R}^{n \times n}: p \in \mathcal{P}\}$ for which

$$\bar{Q}_p \bar{A}_p + \bar{A}'_p \bar{Q}_p < 0, \quad \bar{R}(p, q)' \bar{Q}_p \bar{R}(p, q) \leq \bar{Q}_q, \tag{29}$$

$$p, q \in \mathcal{P}.$$

Then, because of Lemma 1, $S(\sigma)$ is exponentially stable, uniformly over \mathcal{S} and its state x and output u_C remain bounded for every $\sigma \in \mathcal{S}$. Because of (27), e_T is then also bounded, as well as all other signals. Moreover, if $r = d = n = 0$ then e converges to zero exponentially fast, because of (28), and so does u_C and all the remaining signals.

It turns out that the overall closed-loop switched system (7)–(9), with the multi-controller built as above, is exponentially stable, uniformly over \mathcal{S} . This means that the properties derived above (namely, the boundedness of its state and convergence to zero in the absence of exogenous inputs) are robust with respect to small perturbations to the dynamics of the system (cf. Remark 2). In particular, these properties hold even if the “copy” of the process inside the multi-controller does not match exactly the real process. The fact that (7)–(9) is exponentially stable will be proved below for the general case.

Remark 4. The choice of reset maps for which (29) holds is always possible. Either by enforcing complete reset, i.e., $\bar{R}(p, q) = 0$, for all $p, q \in \mathcal{P}$, or by avoiding reset altogether through the choice of realizations for the $\{S_p: p \in \mathcal{P}\}$, for which there is a common quadratic Lyapunov function. The latter is always possible as seen in Lemma 7 in the appendix.

4.2. General linear time-invariant process

The reader familiar with the Youla parameterization (Youla et al., 1976) probably recognized (24) as the general form of any controller that stabilizes the stable process H_P . It is well known that this formula can be generalized to multiple-input/multiple-output unstable linear time-invariant processes. We shall see shortly that the general formula is still amenable to the construction of multi-controllers adequate for stable switching.

Consider a multiple-input/multiple-output, possibly unstable, process transfer function H_P . To proceed we pick some controller transfer matrix K that stabilizes H_P . For example, one can take K to be one of the elements of \mathcal{K} .

Because K stabilizes $H_{\mathbf{P}}$, it is known⁷ that there exist matrices A_E, B_E, C_E, D_E, F_E , and G_E (with appropriate dimensions) such that A_E is a stability matrix, and $\{A_E + D_E C_E, B_E, C_E\}$ and $\{A_E - B_E F_E, D_E - B_E G_E, F_E, G_E\}$ are stabilizable and detectable realizations of $H_{\mathbf{P}}$ and K , respectively.

Suppose that, for each $p \in \mathcal{P}$, we define

$$S_p := (-Y_C + X_C K_p)(X_{\mathbf{P}} + Y_{\mathbf{P}} K_p)^{-1}, \quad (30)$$

where the four transfer matrices $X_C, Y_C, Y_{\mathbf{P}}$, and $X_{\mathbf{P}}$ are defined by

$$\begin{bmatrix} X_C & -Y_C \\ Y_{\mathbf{P}} & X_{\mathbf{P}} \end{bmatrix} := \begin{bmatrix} F_E \\ C_E \end{bmatrix} (sI - A_E)^{-1} \begin{bmatrix} B_E & -D_E \end{bmatrix} + \begin{bmatrix} I & -G_E \\ 0 & I \end{bmatrix}. \quad (31)$$

Using the fact that K_p stabilizes $H_{\mathbf{P}}$ it is possible to establish that the poles of S_p must have negative real part. A straightforward derivation of this, using state-space methods, can be found in the appendix. This can also be proved using transfer function methods (cf. Remark 10 in Appendix A).

Solving (30) for K_p , we obtain

$$K_p = (X_C - S_p Y_{\mathbf{P}})^{-1} (Y_C + S_p X_{\mathbf{P}}). \quad (32)$$

Therefore the transfer function K_p from $\mathbf{e}_{\mathbf{T}}$ to u_C can be defined implicitly by the following system of equations:

$$\begin{bmatrix} \bar{u} \\ e \end{bmatrix} = \begin{bmatrix} X_C - I & -Y_C \\ Y_{\mathbf{P}} & X_{\mathbf{P}} \end{bmatrix} \circ \begin{bmatrix} u_C \\ \mathbf{e}_{\mathbf{T}} \end{bmatrix}, \quad v = S_p \circ e, \quad (33)$$

$$u_C = v - \bar{u}.$$

This is because we conclude from (33) that

$$\begin{aligned} u_C = v - \bar{u} &= S_p \circ (Y_{\mathbf{P}} \circ u_C + X_{\mathbf{P}} \circ \mathbf{e}_{\mathbf{T}}) \\ &\quad - (X_C \circ u_C - u_C - Y_C \circ \mathbf{e}_{\mathbf{T}}) \\ &= -(X_C - I - S_p Y_{\mathbf{P}}) \circ u_C + (Y_C + S_p X_{\mathbf{P}}) \circ \mathbf{e}_{\mathbf{T}} \end{aligned}$$

and therefore

$$(X_C - S_p Y_{\mathbf{P}}) \circ u_C = (Y_C + S_p X_{\mathbf{P}}) \circ \mathbf{e}_{\mathbf{T}}.$$

The transfer function in (32) follows directly. Pick now a realization $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ for S_p . Because of (31), the system of equations (33) can be realized as

$$\dot{x} = \bar{A}_p x + \bar{B}_p e, \quad v = \bar{C}_p x + \bar{D}_p e, \quad (34)$$

$$\dot{x}_E = A_E x_E + B_E u_C - D_E \mathbf{e}_{\mathbf{T}}, \quad e = C_E x_E + \mathbf{e}_{\mathbf{T}}, \quad (35)$$

$$u_C = -F_E x_E + G_E \mathbf{e}_{\mathbf{T}} + v \quad (36)$$

which must then realize K_p . It is important to note that only (34) changes from controller to controller. We shall use (33)—or more precisely, its state space version (34)–(36)—to guide us in constructing the multi-controller. Indeed, (33) will replace Eq. (25) used in Section 4.1 for the same effect. The following steps are required:

- (1) Pick stabilizable and detectable n_S -dimensional realizations $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ for each $S_p, p \in \mathcal{P}$, defined by (30).
- (2) Define $\mathbf{S}(\sigma)$ to be the system with impulse effects defined by

$$\dot{x} = \bar{A}_\sigma x + \bar{B}_\sigma e, \quad v = \bar{C}_\sigma x + \bar{D}_\sigma e,$$

on intervals where σ is constant and by

$$x(t) = \bar{R}(\sigma(t), \sigma(t^-)) x(t^-),$$

at each switching time t of σ . The reset matrices $\{\bar{R}(p, q): p, q \in \mathcal{P}\}$ should be chosen so that there exist symmetric, positive definite matrices $\{\bar{Q}_p \in \mathbb{R}^{n \times n}: p \in \mathcal{P}\}$, such that

$$\bar{Q}_p \bar{A}_p + \bar{A}_p' \bar{Q}_p < 0, \quad \bar{R}(p, q)' \bar{Q}_p \bar{R}(p, q) \leq \bar{Q}_q, \quad p, q \in \mathcal{P}. \quad (37)$$

Because of Lemma 1, $\mathbf{S}(\sigma)$ is exponentially stable, uniformly over \mathcal{S} . Also here, the choice of reset maps for which (37) holds is always possible (cf. Remark 4).

- (3) Realize the switching controller as

$$\dot{x}_E = A_E x_E + B_E u_C - D_E \mathbf{e}_{\mathbf{T}}, \quad e = C_E x_E + \mathbf{e}_{\mathbf{T}},$$

$$u_C = -F_E x_E + G_E \mathbf{e}_{\mathbf{T}} + v,$$

where e and v are the input and output of $\mathbf{S}(\sigma)$, respectively. This corresponds to the multi-controller in (5)–(6) with

$$F_p := \begin{bmatrix} A_E - B_E F_E + B_E \bar{D}_p C_E & B_E \bar{C}_p \\ \bar{B}_p C_E & \bar{A}_p \end{bmatrix}, \quad (38)$$

$$G_p := \begin{bmatrix} -D_E + B_E (\bar{D}_p + G_E) \\ \bar{B}_p \end{bmatrix},$$

$$H_p := [-F_E + \bar{D}_p C_E \quad \bar{C}_p], \quad J_p := \bar{D}_p + G_E \quad (39)$$

and

$$R_C(p, q) := \begin{bmatrix} I & 0 \\ 0 & \bar{R}(p, q) \end{bmatrix}. \quad (40)$$

As in the case of single-input/single-output stable processes, it is possible to show that the signal e is independent of σ and remains bounded. However, instead of proceeding along this line of reasoning, we shall show directly that

⁷ Cf. Lemma 8 in Appendix A, which is a reformulation of results that can be found in Youla et al. (1976), Francis (1985), Tay, Moore, and Horowitz (1989).

the overall closed-loop switched system (7)–(9), with the multi-controller built as above, is exponentially stable, uniformly over \mathcal{S} .

Theorem 5. *There exist symmetric matrices $\{Q_p: p \in \mathcal{P}\}$ for which (18)–(19) hold with $\{A_p, R(p, q): p, q \in \mathcal{P}\}$ as in (8) and (10), where the process realization $\{A, B, C\}$ is given by*

$$A := A_E + D_E C_E, \quad B := B_E, \quad C := C_E, \quad (41)$$

the controller realizations $\{F_p, G_p, H_p, J_p: p \in \mathcal{P}\}$ are given by (38)–(39), and the controller reset matrices $\{R_C(p, q): p, q \in \mathcal{P}\}$ are given by (40). The closed-loop system with impulse effects (7)–(9) is therefore exponentially stable, uniformly over \mathcal{S} .

Before proving Theorem 5, it should be noted that, in general, the realizations given by (38)–(39) are not minimal. However, denoting by n_K the McMillan degree of K , by n_H the McMillan degree of H_P , and by $n_{\mathcal{K}}$ the McMillan degree of the transfer matrix in \mathcal{K} with largest McMillan degree, the size of A_E need not be larger than $n_H + n_K$ (cf. Lemma 8) and therefore the dimension of the state of the realizations (38)–(39) need not be larger than $2(n_H + n_K) + n_{\mathcal{K}}$ no matter what the number of controllers in \mathcal{K} is. When K is chosen to have the structure of an observer with state feedback, i.e., when H_P and K have realizations $\{A, B, C\}$ and $\{A + HC - BF, H, F\}$, respectively, the size of the matrix A_E need not be larger than n_H (cf. Remark 9) and therefore the dimension of the state of the realizations (38)–(39) can be reduced to $2n_H + n_{\mathcal{K}}$.

Proof. Replacing (38)–(39) and (41) in (8), one obtains for the closed-loop system:

$$A_p = \begin{bmatrix} A_E + D_E C_E - B_E(\bar{D}_p + G_E)C_E & -B_E F_E + B_E \bar{D}_p C_E & B_E \bar{C}_p \\ D_E C_E - B_E(\bar{D}_p + G_E)C_E & A_E - B_E F_E + B_E \bar{D}_p C_E & B_E \bar{C}_p \\ -\bar{B}_p C_E & \bar{B}_p C_E & \bar{A}_p \end{bmatrix}, \quad p \in \mathcal{P}.$$

Defining $T := \begin{bmatrix} I & 0 & 0 \\ 0 & 0 & I \\ -I & I & 0 \end{bmatrix}$, one further concludes that

$$T A_p T^{-1} = \begin{bmatrix} A_E + D_E C_E - B_E F_E - B_E G_E C_E & B_E \bar{C}_p & -B_E F_E + B_E \bar{D}_p C_E \\ 0 & \bar{A}_p & \bar{B}_p C_E \\ 0 & 0 & A_E \end{bmatrix}. \quad (42)$$

Here, we used the fact that $T^{-1} = \begin{bmatrix} I & 0 & 0 \\ I & 0 & I \\ 0 & I & 0 \end{bmatrix}$. Since K stabilizes H_P and $\{A_E + D_E C_E, B_E, C_E\}$ and $\{A_E - B_E F_E,$

$D_E - B_E G_E, F_E, G_E\}$ are stabilizable and detectable realizations of H_P and K , respectively, the matrix

$$\bar{A}_E := \begin{bmatrix} A_E + D_E C_E - B_E G_E C_E & B_E F_E \\ -(D_E - B_E G_E)C_E & A_E - B_E F_E \end{bmatrix} \quad (43)$$

is asymptotically stable (cf. right-hand side of (43) against (4)). Therefore,

$$T_E \bar{A}_E T_E^{-1} = \begin{bmatrix} A_E + D_E C_E - B_E F_E - B_E G_E C_E & B_E F_E \\ 0 & A_E \end{bmatrix},$$

with $T_E := \begin{bmatrix} I & 0 \\ I & I \end{bmatrix}$, $T_E^{-1} = \begin{bmatrix} I & 0 \\ -I & I \end{bmatrix}$ is also asymptotically stable. The matrices $A_E + D_E C_E - B_E F_E - B_E G_E C_E$ and A_E must then be asymptotically stable and so there exist positive definite symmetric matrices Q_1, Q_2 such that

$$Q_1(A_E + D_E C_E - B_E F_E - B_E G_E C_E) + (A_E + D_E C_E - B_E F_E - B_E G_E C_E)' Q_1 = -I, \quad (44)$$

$$Q_2 A_E + A_E' Q_2 = -I. \quad (45)$$

Moreover, because of (37), each

$$P_p := -\bar{Q}_p \bar{A}_p - \bar{A}_p' \bar{Q}_p, \quad p \in \mathcal{P},$$

is positive definite. Therefore, there must exist a positive constant ε , sufficiently small, such that

$$P_p - \varepsilon \bar{Q}_p \bar{B}_p C_E C_E' \bar{B}_p' \bar{Q}_p > 0, \quad \forall p \in \mathcal{P},$$

which guarantees that each

$$R_p := \varepsilon \begin{bmatrix} P_p & -\bar{Q}_p \bar{B}_p C_E \\ -C_E' \bar{B}_p' \bar{Q}_p & \varepsilon^{-1} I \end{bmatrix}, \quad p \in \mathcal{P}, \quad (46)$$

is also positive definite (cf. Boyd et al., 1994, Section 2.1).

Let now

$$Q_p := T' \begin{bmatrix} \varepsilon_1 Q_1 & 0 & 0 \\ 0 & \varepsilon \bar{Q}_p & 0 \\ 0 & 0 & Q_2 \end{bmatrix} T \quad (47)$$

with

$$\varepsilon_1 := \frac{1}{2} \left(\max_{p \in \mathcal{P}} \|Q_1 S_p R_p^{-1} S_p' Q_1\| \right)^{-1}, \quad (48)$$

where, for each $p \in \mathcal{P}$,

$$S_p := [B_E \bar{C}_p \quad -B_E F_E + B_E \bar{D}_p C_E]. \quad (49)$$

From (42), (44)–(45), (46), (47), and (49) one concludes that

$$Q_p A_p + A_p' Q_p = -\varepsilon_1 T' \begin{bmatrix} I & -Q_1 S_p \\ -S_p' Q_1 & \varepsilon_1^{-1} R_p \end{bmatrix} T, \quad p \in \mathcal{P}. \quad (50)$$

But, because of (48), $I - \varepsilon_1 Q_1 S_p R_p^{-1} Q_1 S_p > 0$ for each $p \in \mathcal{P}$, thus

$$\begin{bmatrix} I & -Q_1 S_p \\ -S_p' Q_1 & \varepsilon_1^{-1} R_p \end{bmatrix} > 0, \quad p \in \mathcal{P}$$

(cf. Boyd et al., 1994, Section 2.1). From this and (50) one concludes that (18) holds.

Inequality (19) is a straightforward consequence of the definitions of the Q_p in (47) and the $R(p, q)$ in (10), (40). Indeed, from these definitions one concludes that

$$R(p, q)' Q_p R(p, q) - Q_q = \begin{bmatrix} 0 & 0 & 0 \\ 0 & 0 & 0 \\ 0 & 0 & \varepsilon(\bar{R}(p, q)' \bar{Q}_p \bar{R}(p, q) - \bar{Q}_q) \end{bmatrix}, \quad p, q \in \mathcal{P}.$$

The matrix on the right-hand side is negative semi-definite because of (37). \square

Remark 6. In Theorem 5, we proved the existence of the matrices $\{Q_p: p \in \mathcal{P}\}$ needed to apply Lemma 1 for a specific realization (41) of the process transfer matrix H_P . This may not be the “actual” realization of the process and not even similar to it (as (41) may not be minimal). However, this is irrelevant as far as the exponential stability of the switched system is concerned because (i) asymptotically stable modes of the process that are not observable do not affect the switched controller and (ii) only the controllable modes of the process can be excited by the multi-controller.

5. Example

In this section, we briefly illustrate how to utilize the results presented above in a design problem. We consider here the control of the roll angle of an aircraft. The following process model was taken from Vegte (1994, p. 381):

$$H_P(s) = \frac{-1000}{s(s + 0.875)(s + 50)}.$$

$$S_1 = 0,$$

$$S_2 = \frac{2187^2(s + 0.9995)(s^2 + 13.26s + 9.319^2)(s + 50.05)(s + 66.24)}{(s + 1)(s^2 + 93.94s + 56.23^2)(s^2 + 465.1s + 463.7^2)(s + 465.1)}.$$

Ideally, one would like to design a controller that is both fast and has good measurement noise rejection properties. Clearly this is not possible, as increasing the bandwidth of the closed-loop system will also make the system more sensitive to measurement noise. We opt then to design two distinct controllers: Controller K_1 has low closed-loop bandwidth and is therefore not very sensitive to noise but exhibits a slow response. Controller K_2 has high bandwidth and is therefore fast but very sensitive to noise. Both

controllers were designed using LQG/LQR. We computed the regulator gains by minimizing the cost

$$J_{\text{reg}} := \int_0^\infty y^2(\tau) + \dot{y}^2(\tau) + \rho u^2(\tau) d\tau,$$

where ρ was chosen equal to 100 and 0.1 for K_1 and K_2 , respectively. These choices of ρ resulted in K_2 exhibiting a much fast response than K_1 . The design of the optimal LQG gain was done assuming that the input disturbance \mathbf{d} and the measurement noise \mathbf{n} were uncorrelated white noise processes with

$$E[\mathbf{d}(t)\mathbf{d}(\tau)] = \delta(t - \tau), \quad E[\mathbf{n}(t)\mathbf{n}(\tau)] = \mu\delta(t - \tau),$$

where μ was chosen equal to 10^{-1} and 10^{-10} for K_1 and K_2 , respectively. These choices of μ resulted in K_1 exhibiting much better noise rejection properties than K_2 . The controller transfer functions obtained were:

$$K_1 \approx \frac{-6.694(s + 0.9446)(s + 50.01)}{(s^2 + 13.23s + 9.453^2)(s + 50.05)},$$

$$K_2 \approx \frac{-2187^2(s + 0.9977)(s + 66.28)}{(s^2 + 467.2s + 486.2^2)(s + 507)}.$$

The two left plots in Fig. 6 show the closed-loop response of controllers K_1 and K_2 to a square reference. Large measurement noise was injected into the system for $t \in [18, 40]$. By design, controller K_1 exhibits a faster response but is more sensitive to measurement noise.

To design the multi-controller for $\mathcal{K} := \{K_1, K_2\}$ we followed the procedure given in Section 4.2: We started by selecting matrices $A_E, B_E, C_E, D_E, F_E,$ and G_E such that A_E is a stability matrix, and $\{A_E + D_E C_E, B_E, C_E\}$ and $\{A_E - B_E F_E, D_E - B_E G_E, F_E, G_E\}$ are stabilizable and detectable realizations of H_P and $K := K_1$, respectively. Since K has the structure of an observer with state feedback, we used the formulas in Remark 9 for these matrices. The corresponding transfer matrices $\{S_1, S_2\}$ were then computed using (30):

The fact that $S_1 = 0$ is a consequence of having used $K := K_1$ (cf. Remark 10). We then picked a minimal realization $\{\bar{A}_2, B_2, C_2\}$ for S_2 and the trivial realization $\{\bar{A}_2, 0, \bar{C}_2\}$ for S_1 . Since both realization share the same stable \bar{A}_2 matrix, (37) holds with $\bar{Q}_1 = \bar{Q}_2$ and $\bar{R}(1, 2) = \bar{R}(2, 1) = I$. As mentioned before, it would have been possible to choose realization for S_1 and S_2 with this property even if S_1 was nontrivial. The desired controller realizations are then given by (38)–(39), and the controller reset matrices are simply the identity (i.e., no reset is used). These guarantee




Fig. 6. Closed-loop response of controllers K_1 , K_2 , and the switched multi-controller to a square reference r . Large measurement noise \mathbf{n} was injected into the system in the interval $t \in [18, 40]$. The top plots show the output y and the bottom plots the tracking error $\mathbf{e}_T := \mathbf{r} - y - \mathbf{n}$. For the switched controller, K_1 was used in the interval $t \in [22, 42]$ and K_2 in the remaining time.

that the switched closed-loop system is exponentially stable, uniformly over \mathcal{S} .

The rightmost plot in Fig. 6 shows the closed-loop response of the switched controller. In this figure, controller K_2 was used until time $t = 22$ (shortly after the measurement noise increased). At that point there was a switch to controller K_1 , resulting in significant noise rejection. Controller K_1 was used until time $t = 42$ (shortly after the measurement noise decreased back to the original level). The construction of a logic that actually commands the switching between controllers is beyond the scope of this paper. The contribution here is the implementation of the multi-controller so that we have stability *regardless of the switching signal* σ . Once stability is guaranteed, one can use very simple-minded algorithms to decide how to switch between the controllers. For example, one could use controller K_2 only when there is low high-frequency content in the tracking error \mathbf{e}_T .

6. Conclusions

In the control of complex systems, conflicting requirements often make a single linear time-invariant controller unsuitable. One can then be tempted to design several controllers, each suitable for a specific operating condition, and switch among them to achieve the best possible performance. Unfortunately, it is well known that the transients caused by switching may cause instability. We showed here that instability can be avoided by suitable choice of the realizations for the controllers.

An important question for future research is the design of logics that orchestrate the switching among controllers to improve performance. The results in this paper greatly sim-

plify the design of such logics since stability of the switched system is no longer an issue. Another question that needs to be investigated is the simultaneous switching of process and controller. In particular, suppose that the process to be controlled switches in an unpredictable fashion and that we would like to switch controllers to keep the closed-loop system stable. Can we choose realizations for the controllers so that the process/controller switched system is stable? An affirmative answer to this question would have a profound impact both in gain-scheduling and in multiple-model supervisory control (cf. Morse, 1996; Morse, 1997; Hespanha et al., 2001).

Acknowledgements

The authors would like to thank Daniel Liberzon, David Mayne, and Andrew Teel for useful discussion related to this work; and also the anonymous reviewers for several constructive suggestions that found their way into the final version of the paper. The authors would also like to point out that Andrew Packard has independent unpublished work on the problem addressed in this paper. We thank Kameshwar Poolla for bringing this to our attention.

Appendix A.

A.1. Realizations for stable transfer matrices

This section addresses a simpler problem than the one formulated before. Consider a finite family of *asymptotically stable* transfer matrices $\mathcal{A} = \{S_p; p \in \mathcal{P}\}$. It is

shown below how to compute stabilizable and detectable n -dimensional realizations $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ for each $S_p \in \mathcal{A}$ such that

$$Q\bar{A}_p + \bar{A}'_p Q < 0, \quad p \in \mathcal{P}, \quad (\text{A.1})$$

for some symmetric positive definite matrix $Q \in \mathbb{R}^{n \times n}$. With such a matrix it is then possible to construct a common Lyapunov function $V(z) = z'Qz$ for the family of linear time-invariant systems $\{\dot{z} = \bar{A}_p z; p \in \mathcal{P}\}$.

Let n be the McMillan degree of the transfer matrix in \mathcal{A} with largest McMillan degree and, for each $p \in \mathcal{P}$, let $\{\tilde{A}_p, \tilde{B}_p, \tilde{C}_p, \tilde{D}_p\}$ be any n -dimensional realization of S_p , with \tilde{A}_p asymptotically stable. Because of the asymptotic stability of each \tilde{A}_p , $p \in \mathcal{P}$ the family of Lyapunov equations

$$Q_p \tilde{A}_p + \tilde{A}'_p Q_p = -I, \quad p \in \mathcal{P} \quad (\text{A.2})$$

must have symmetric positive definite solutions Q_p , which can be written as $Q_p = S'_p S_p$ with S_p nonsingular. For a given positive definite matrix $Q = S'S \in \mathbb{R}^{n \times n}$ with S nonsingular, let

$$\begin{aligned} \bar{A}_p &:= S^{-1} S_p \tilde{A}_p S_p^{-1} S, & \bar{B}_p &:= S^{-1} S_p \tilde{B}_p, & \bar{C}_p &:= \tilde{C}_p S_p^{-1} S, \\ \bar{D}_p &:= \tilde{D}_p. \end{aligned} \quad (\text{A.3})$$

Since $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ is obtained from $\{\tilde{A}_p, \tilde{B}_p, \tilde{C}_p, \tilde{D}_p\}$ by a similarity transformation, $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ is also a realization of S_p . Moreover, from (A.2) and (A.3) we conclude that

$$(S^{-1} S_p)' (Q \bar{A}_p + \bar{A}'_p Q) S^{-1} S_p = -I.$$

Left and right multiplication of the above equality by $(S_p^{-1} S)'$ and $S_p^{-1} S$, respectively, yields

$$Q \bar{A}_p + \bar{A}'_p Q = -(S_p^{-1} S)' S_p^{-1} S < 0$$

and therefore one concludes that (A.1) holds. The following was proved:

Lemma 7. *Given any finite family of asymptotically stable transfer matrices $\mathcal{A} = \{S_p; p \in \mathcal{P}\}$ with McMillan degree no larger than n and any symmetric positive definite $n \times n$ matrix Q , there exist stabilizable and detectable n -dimensional realizations $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$ for each $S_p \in \mathcal{A}$ such that (A.1) holds.*

A.2. Technical lemmas

Lemma 8. *Given two transfer matrices N and K , with N strictly proper, such that K stabilizes N , there exist matrices A_E, B_E, C_E, D_E, F_E , and G_E (with appropriate dimensions) such that A_E is a stability matrix, and $\{A_E + D_E C_E, B_E, C_E\}$ and $\{A_E - B_E F_E, D_E - B_E G_E, F_E, G_E\}$ are stabilizable and detectable realizations of $H_{\mathbf{P}}$ and K , respectively.*

Proof. Let $\{A, B, C\}$ and $\{F, G, H, J\}$ be minimal realizations of $H_{\mathbf{P}}$ and K , respectively, and X, Y matrices such that $A + XC$ and $F + YH$ are asymptotically stable. Defining

$$A_E := \begin{bmatrix} A + XC & 0 \\ 0 & F + YH \end{bmatrix}, \quad B_E := \begin{bmatrix} B \\ -Y \end{bmatrix},$$

$$D_E := \begin{bmatrix} -X \\ -G - YJ \end{bmatrix}, \quad C_E := [C \ 0],$$

$$F_E := [0 \ -H], \quad G_E := J,$$

the matrix A_E is asymptotically stable and

$$\begin{aligned} & C_E (sI - A_E - D_E C_E)^{-1} B_E \\ &= [C \ 0] \left(sI - \begin{bmatrix} A & 0 \\ -GC - YJC & F + YH \end{bmatrix} \right)^{-1} \begin{bmatrix} B \\ -Y \end{bmatrix} \\ &= H_{\mathbf{P}}(s), \end{aligned}$$

$$\begin{aligned} & F_E (sI - A_E + B_E F_E)^{-1} (D_E - B_E G_E) + G_E \\ &= [0 \ -H] \left(sI - \begin{bmatrix} A + XC & BH \\ 0 & F \end{bmatrix} \right)^{-1} \begin{bmatrix} -X - BJ \\ -G \end{bmatrix} + J \\ &= K(s). \end{aligned}$$

Detectability of $\{C_E, A_E + D_E C_E\}$ and $\{F_E, A_E - B_E F_E\}$ is guaranteed by the fact that both $A_E + D_E C_E$ and $A_E - B_E F_E$ are an output injection away from A_E which is a stability matrix. Stabilizability of $\{A_E + D_E C_E, B_E\}$ and $\{A_E - B_E F_E, D_E - B_E G_E\}$ is guaranteed by the fact that both $A_E + D_E C_E$ and $A_E - B_E F_E$ are a state feedback away from

$$\begin{bmatrix} A - BJC & BH \\ -GC & F \end{bmatrix},$$

which is a stability matrix since K stabilizes $H_{\mathbf{P}}$. \square

Remark 9. When K is chosen to have the structure of an observer with state feedback, i.e., when $H_{\mathbf{P}}$ and K have realizations $\{A, B, C\}$ and $\{A + HC - BF, H, F\}$, respectively, one can simply pick $A_E = A + HC$, $B_E = B$, $C_E = C$, $D_E = -H$, $F_E = F$, and $G_E = 0$.

Verification of the stability of the S_p , $p \in \mathcal{P}$: Straight-forward algebra shows that the transfer function on the right-hand side of (30) is equal to the transfer function from e to v defined by the system of equations

$$\begin{bmatrix} v \\ \bar{y} \end{bmatrix} = \begin{bmatrix} X_C & -Y_C \\ Y_P & X_P - I \end{bmatrix} \circ \begin{bmatrix} \bar{u} \\ e - \bar{y} \end{bmatrix}, \quad \bar{u} = K_p \circ (e - \bar{y}). \quad (\text{A.4})$$

Now, because of (31),

$$\left\{ A_E, [B_E \ -D_E], \begin{bmatrix} F_E \\ C_E \end{bmatrix}, \begin{bmatrix} I & -G_E \\ 0 & 0 \end{bmatrix} \right\}$$

is a realization for $\begin{bmatrix} X_C & -Y_C \\ Y_P & X_P - I \end{bmatrix}$. Thus, picking any minimal realization $\{\hat{A}_p, \hat{B}_p, \hat{C}_p, \hat{D}_p\}$ of K_p , the system (A.4) can be realized as

$$\begin{aligned} \dot{x}_E &= A_E x_E + B_E \bar{u} - D_E(e - \bar{y}), \quad \bar{y} = C_E x_E, \\ \dot{\hat{x}} &= \hat{A}_p \hat{x} + \hat{B}_p(e - \bar{y}), \quad \bar{u} = \hat{C}_p \hat{x} + \hat{D}_p(e - \bar{y}), \\ v &= F_E x_E + \bar{u} - G_E(e - \bar{y}). \end{aligned}$$

Therefore, the transfer function from e to v in (A.4) (and therefore S_p) can be realized by $\{\bar{A}_p, \bar{B}_p, \bar{C}_p, \bar{D}_p\}$, with

$$\bar{A}_p := \begin{bmatrix} A_E + D_E C_E - B_E \hat{D}_p C_E & B_E \hat{C}_p \\ -\hat{B}_p C_E & \hat{A}_p \end{bmatrix}, \quad (\text{A.5})$$

and $\bar{B}_p, \bar{C}_p, \bar{D}_p$ appropriately defined. Since K_p stabilizes H_P and $\{A_E + D_E C_E, B_E, C_E\}$ is a stabilizable and detectable realization of H_P , \bar{A}_p must be asymptotically stable (cf. \bar{A}_p in (A.5) against (4)). Thus, for each $p \in \mathcal{P}$, the poles of S_p must also have negative real part.

Remark 10. Denoting by RH_∞ the ring of transfer matrices whose entries are proper, stable rational functions with real coefficients, the transfer matrices X_P, Y_P, Y_C, X_C defined in (31) form a simultaneous right-coprime factorization of H_P and K in the sense that X_P and X_C have causal inverse, $\begin{bmatrix} X_C & -Y_C \\ Y_P & X_P - I \end{bmatrix}$ is a unit in RH_∞ , and $H_P = X_P^{-1} Y_P$ and $K = X_C^{-1} Y_C$. Thus, the existence of the family of stable transfer matrices $\{S_p: p \in \mathcal{P}\} \subset RH_\infty$ such that (32) holds is not surprising in light of the parameterization of all controllers that stabilize H_P , given by Youla et al. (1976). Note also that since $K = X_C^{-1} Y_C$, if one chooses $K = K_{p_0}$ for some $p_0 \in \mathcal{P}$, then the corresponding transfer matrix S_{p_0} given by (30) with $p = p_0$ is equal to 0.

References

- Bainov, D. D., & Simeonov, P. S. (1989). *Systems with impulse effects: Stability, theory and applications*. New York: Academic Press.
- Boyd, S. P., & Barratt, C. H. (1991). *Linear controller design: Limits of performance*. New Jersey: Prentice-Hall.
- Boyd, S., Ghaoui, L. E., Feron, E., & Balakrishnan, V. (1994). Linear matrix inequalities in system and control theory. In *SIAM studies in applied mathematics*, Vol. 15. Philadelphia, PA: SIAM.
- Branicky, M. S. (1998). Multiple Lyapunov functions and other analysis tools for switched and hybrid systems. *IEEE Transactions on Automatic Control*, 43, 475–482.
- Clegg, J. C. (1958). A nonlinear integrator for servo-mechanisms. *AIEE Transactions, Part II, Applications and Industry*, 77, 41–42.

- Dayawansa, W. P., & Martin, C. F. (1999). A converse Lyapunov theorem for a class of dynamical systems which undergo switching. *IEEE Transactions on Automatic Control*, 44, 751–760.
- Eker, J., & Malmberg, J. (1999). Design and implementation of a hybrid control strategy. *IEEE Control and Systems Magazine*, 19, 12–21.
- Francis, B. A. (1985). A course in \mathcal{H}_∞ control theory. In *Lecture notes in control and information sciences*, Vol. 88. New York: Springer.
- Gurvits, L. (1996). *Stability of linear inclusions—Part 2*. Technical Report, NECI.
- Hespanha, J. P. (1998). *Logic-based switching algorithms in control*. Ph.D. thesis, Yale University, New Haven, CT.
- Hespanha, J. P., Liberzon, D., Morse, A. S., Anderson, B. D. O., Brinsmead, T. S., & de Bruyne, F. (2001). Multiple model adaptive control, part 2: Switching. *International Journal of Robust and Nonlinear Control* (Special Issue on Hybrid Systems in Control), 11, 479–496.
- Hespanha, J. P., & Morse, A. S. (1996). Towards the high performance control of uncertain processes via supervision. In *Proceedings of the 30th annual conference on information sciences and systems 1*, 405–410.
- Hollot, C. V., Beker, O., & Chait, Y. (2001). Plant with integrator: An example of reset control overcoming limitations of linear feedback. In *Proceedings of the 2001 American control conference*, Vol. 2 (pp. 1519–1520).
- Horowitz, I., & Rosenbaum, P. (1975). Non-linear design for cost of feedback reduction in systems with large parameter uncertainty. *International Journal of Control*, 24(6), 977–1001.
- Khalil, H. K. (1992). *Nonlinear systems*. New York: Macmillan.
- Liberzon, D., Hespanha, J. P., & Morse, A. S. (1999). Stability of switched linear systems: A Lie-algebraic condition. *Systems and Control Letters*, 37, 117–122.
- Liberzon, D., & Morse, A. S. (1999). Basic problems in stability and design of switched systems. *IEEE Control Systems and Magazine*, 19, 59–70.
- Megretski, A., & Rantzer, A. (1997). System analysis via integral quadratic constraints. *IEEE Transactions on Automatic Control*, 42, 819–830.
- Molchanov, A. P., & Pyatnitskiy, Y. S. (1989). Criteria of asymptotic stability of differential and difference inclusions encountered in control theory. *Systems and Control Letters*, 13, 59–64.
- Morse, A. S. (1995). Control using logic-based switching. In A. Isidori (Ed.), *Trends in control: An European perspective* (pp. 69–113). London: Springer.
- Morse, A. S. (1996). Supervisory control of families of linear set-point controllers—Part 1: Exact matching. *IEEE Transactions on Automatic Control*, 41, 1413–1431.
- Morse, A. S. (1997). Supervisory control of families of linear set-point controllers—Part 2: Robustness. *IEEE Transactions on Automatic Control*, 2, 1500–1515.
- Narendra, K. S., & Balakrishnan, J. (1994). A common Lyapunov function for stable LTI systems with commuting A -matrices. *IEEE Transactions on Automatic Control*, 39, 2469–2471.
- Packard, A. (1995). Personal communication.
- Shorten, R. N., & Narendra, K. S. (1997). A sufficient condition for the existence of a common Lyapunov function for two second order linear systems. In *Proceedings of the 36th conference on decision and control*, 4, 3521–3522.
- Tay, T. T., Moore, J. B., & Horowitz, R. (1989). Indirect adaptive techniques for fixed controller performance enhancement. *International Journal of Control*, 50, 1941–1959.
- Tsitsiklis, J. N., & Blondel, V. D. (1997). The Lyapunov exponent and joint spectral radius of pairs of matrices are hard—when not impossible—to compute and to approximate. *Mathematics of Control, Signals and Systems*, 10(1), 31–40.
- Vegete, J. V. (1994). *Feedback control systems* (3rd ed.). New Jersey: Prentice-Hall.

- Ye, H., Michel, A. N., & Hou, L. (1998). Stability theory for hybrid dynamical systems. *IEEE Transactions on Automatic Control*, 43, 461–474.
- Yoshihiro Mori, T. M., & Kuroe, Y. (1997). A solution to the common Lyapunov function problem for continuous-time systems. In *Proceedings of the 36th conference on decision and control*, Vol. 3 (pp. 3530–3531).
- Youla, D. C., Jabr, H. A., & Bongiorno, J. J. (1976). Modern Wiener-Hopf design of optimal controllers—part II. The multivariable case. *IEEE Transactions on Automatic & Control*, 21, 319–338.



João P. Hespanha was born in Coimbra, Portugal, in 1968. He received the Licenciatura and the M.S. degree in electrical and computer engineering from Instituto Superior Técnico, Lisbon, Portugal, in 1991 and 1993, respectively, and the M.S. and Ph.D. degrees in electrical engineering and applied science from Yale University, New Haven, Connecticut, in 1994 and 1998, respectively. For his Ph.D. work, Dr. Hespanha received Yale University's Henry Prentiss Becton Graduate

Prize for exceptional achievement in research in Engineering and Applied Science. Dr. Hespanha currently holds an Associate Professor position at the University of California, Department of Electrical and Computer Engineer, Santa Barbara. From 1999 to 2001 he was an Assistant Professor at the University of Southern California, Los Angeles. Dr. Hespanha's research interests include nonlinear control, both robust and adaptive; hybrid systems; switching control; the use of vision in feedback control;

and probabilistic games. Dr. Hespanha is the author of over 80 technical papers, the recipient of a NSF CAREER Award (2001), and the PI and co-PI in several federally funded projects.



A. Stephen Morse was born in Mt. Vernon, New York. He received a B.S.E.E. degree from Cornell University, Ithaca, in 1962, a M.S. degree from the University of Arizona, Tucson, in 1964, and a Ph.D. degree from Purdue University, West Lafayette, in 1967, all in electrical engineering. From 1967 to 1970 he was associated with the Office of Control Theory and Application, NASA Electronics Research Center, Cambridge, Mass. Since July, 1970 he has been with Yale Uni-

versity where he is presently a Professor of Electrical Engineering. His main interest is in system theory, and he has done research in network synthesis, optimal control, multivariable control, adaptive control, urban transportation, hybrid and nonlinear systems, and most recently coordination and control of groups of mobile autonomous agents. Dr. Morse is a Fellow of the IEEE and a member of SIAM, Sigma Xi and Eta Kappa Nu. He has served as an Associate Editor of the *IEEE Transactions on Automatic Control*, the *European Journal of Control* and the *International Journal of Adaptive Control and Signal Processing* and as a Director of the American Automatic Control Council representing the Society for Industrial and Applied Mathematics. Dr. Morse is a member of the National Academy of Engineering. He was the recipient of the 1999 IEEE Control Systems Award. He is a Distinguished Lecturer of the IEEE Control Systems Society and a co-recipient of the Society's George S. Axelby Outstanding Paper Award. He has twice received the American Automatic Control Council's Best Paper Prize.